


**ORIGINAL**



0000161827



RECEIVED

15 SEP 17 A 11:54

AZ CORP COMMISSION  
DOCKET CONTROL

414 North Court Avenue  
Tucson, Arizona 85701  
(520) 623-2366  
FAX (520) 623-2302

## **COMPLIANCE FILING**

## **COVER SHEET**

For  
Response to Compliance Notice (dated September 1, 2015)

**Docket # W-01380A-12-0254**

**Decision # 74084**

**Submitted by Ray Water Company, Inc.**

**September 16, 2015**

Arizona Corporation Commission  
**DOCKETED**  
SEP 17 2015

DOCKETED BY	TV
-------------	----


Docket # W-01380A-12-0254  
Decision # 74084  
Submitted by Ray Water Company, Inc.  
September 16, 2015

Ray Water Company respectfully submits the following documentation in support of its compliance action, which is required under the Order and Decision # 74084, whereby Ray Water is required to complete the following action:

**ACTION REQUIRED:** IT IS FURTHER ORDERED that Ray Water Company, Inc. shall monitor the water system closely and take action to ensure that annual water loss is less than 10 percent by December 2013. If the reported annual water loss is greater than 10 percent, Ray Water Company, Inc. shall prepare a report containing a detailed analysis and a plan to reduce annual water loss to 10 percent or less. If Ray Water Company, Inc. believes it is not cost effective to reduce the water loss to less than 10 percent, it should submit a detailed cost benefit analysis to support its position. In no case shall annual water loss be greater than 15 percent. The water loss reduction report or detailed analysis, whichever is submitted, shall be docketed as a compliance item within 24 months of the effective date of the effective date of this Decision.

**ACTION TAKEN:** In compliance with the Order in Decision # 74084, Ray Water Company, Inc. monitored its water system closely and recorded, by month, the water pumped and the water sold during the entire year, 2013. During the calendar year, 2013, Ray Water Company, Inc.'s total water loss was less than 10%. Ray Water prepared a spreadsheet, attached to this Compliance Filing, which evidences that the 2013 annual water loss is less than ten percent (10%). Therefore, as per the terms of Decision #74084, Ray Water has hereby fulfilled its obligation to comply with the Order in Decision #74084.

Respectfully submitted,

A handwritten signature in black ink, appearing to read 'Rhonda Mallis Rosenbaum', written over a horizontal line.

Rhonda Mallis Rosenbaum  
General Manager,  
Ray Water Company, Inc.

DOCKET# W-01380A-12-0254

RAY WATER COMPANY, INC.-2013

September 16, 2015

DECISION # 74084

Water Use showing water loss %

	Gallons Pumped (1000s)*	Gallons Sold (1000s)	Difference **	Water Loss (%)
Jan-13	15910	15029	881	
Feb-13	12089	11337	752	
Mar-13	16950	12304	4646	
Apr-13	21664	38652	-16988	
May-13	25454	16630	8824	
Jun-13	24179	23541	638	
Jul-13	21076	17586	3490	
Aug-13	24228	20357	3871	
Sep-13	14878	18023	-3145	
Oct-13	12964	12852	112	
Nov-13	13768	18852	-5084	
Dec-13	14278	12031	2247	
Total 2013	217438	217194	244	0.001122159
	Column1		**negative figures	
	*includes well pump		due to billing cycle	
	breakdown estimate		dates	